

**OFFICE OF ASSISTANT ENGINEER,
P.H. SUB DIVISION, LALGANJ.**

Lt. No. 93 /Lalganj

Date:- 16/02 /2026

TO WHOM IT MAY CONCERN

This is to certify that St. Michael's School at Lalganj, District Vaishali Bihar, on the basis of inspection and Water Test Report (Attached) vide Lt. No. 10 Dt 31.01.2026 of Chemist Sub Divisional Lab Lalganj, has safe drinking water facilities for the students and members of staff of the Institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State Govt. This above is valid for a period of one Year.

Pranav k.
06/02/26
JE

P. H.
16/02/26
Assistant Engineer
P. H. Sub-Division, Lalganj

Letter No:- 10

Date: 31/01/2026

**Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report**

Zone: Muzaffarpur		District: Vaishali		Sub-Division: LalGANJ		Month: Jan 2026																	
Sl. No.	Block	Panchayat	Village	Habitation	Location Details	Type of source (RP-IM, IM, III/Or./PWS-stand/PWS House connection)	Physico-Chemical & Bacteriological parameters																
							pH	Conductivity (µS/cm)	TDS	Turb.	Total Hardness (mg/L)	Calcium (mg/L)	Magnesium (mg/L)	Total Alkalinity (mg/L)	Chloride (mg/L)	Nitrate (mg/L)	Iron (mg/L)	Sulphate (mg/L)	Fluoride (mg/L)	Arsenic (mg/L)	Total Coliform (MPN/100 ml)	Remarks (safe / unsafe)	
1	2	3	4	5	ST. MICHAEL'S SCHOOL, LALGANJ	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	
1	LalGANJ	LalGANJ	LalGANJ	LalGANJ		7.19	173	113	1	80	19	7	92	12	45	0.3	200	1.0	NR	Should not be detected in 100 ml sample			
Desirable limit							6.5-8.5		500	1	200	75	30	200	250					0.01			
Permissible limit in absence of alternate source							NR	--	2000	5	600	200	100	600	1000	No relaxatio	1.0	400	1.5	NR			

NOTE: 1. Bold with underline or Highlight the parameter if the result is beyond permissible limit. 2. Under remarks (safe/unsafe) column, unsafe sources should be bold with underline or to be highlighted 3. BDL-Below Dection Limit

Ratna K. K.
31/01/2026



SD
Chemist/ Assistant
Date: